Capacity correction factors Height difference and pipe length

SYSPLIT CONSOLE 12 LNS HP





| Capacity (Btu/h) | 12K | | Pipe Length (m) | | | |
|-------------------------------|------------------------------|-----|-----------------|-------|-------|-------|
| | | | | | | |
| Cooling | | | 5 | 10 | 20 | 25 |
| Height difference H (m) | Indoor Upper than Outdoor | 10 | | 0.973 | 0.948 | 0.936 |
| | | 5 | 0.995 | 0.983 | 0.958 | 0.945 |
| | | 0 | 1.000 | 0.988 | 0.963 | 0.950 |
| | Outdoor Upper than Indoor | -5 | 1.000 | 0.988 | 0.963 | 0.950 |
| | | -10 | | 0.988 | 0.963 | 0.950 |
| | | | | | | |
| Heating | | | 5 | 10 | 20 | 25 |
| Height difference H (m) | Indoor Upper than Outdoor | 10 | | 0.993 | 0.978 | 0.970 |
| | | 5 | 1.000 | 0.993 | 0.978 | 0.970 |
| | | 0 | 1.000 | 0.993 | 0.978 | 0.970 |
| | Outdoor Upper than Indoor | -5 | 0.992 | 0.985 | 0.970 | 0.962 |
| | | -10 | | 0.977 | 0.962 | 0.955 |

